

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

#### **Division of Technical Services**

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

# Amended

FOR OFFICE USE ONLY

Facility # 2-032441 Permit # 01107-2007INS Request Rec'd 07/23/2007 Amended Date 08/08/2007

Approval Date 7/24/2007 JC Permit Expires 1/24/2008

# <u>Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.</u>

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

٠	(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
	Army Trail Oil, Inc. 539 W. Army Trail Road Addison, IL 60101	Army Trail Oil, Inc. 539 Army Trail Rd. Addison, Du Page Co., IL
	Contact: Emmanual Joseph	Contact: Emmanual Joseph

## (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 5) 10,000 gallons, (TK # 6, 7) 4,000 gallons
- (b) Type of tanks: (TK # 5, 6, 7) (Installing) Permatank double wall composite
- (c) Type of piping: (TK # 5, 6, 7) (Installing) Ameron Dualoy 3000/LCX double wall fiberglass
- (d) Product to be stored in each tank: (TK # 5, 6) Gasoline, (TK # 7) Diesel Fuel
- (e) Type of leak detection being used:

*Tank:* (TK # 5, 6, 7) - (Installing) Veeder Root TLS 350 with CSLD automatic tank gauge, (TK # 5, 6, 7) - (Installing) Veeder Root TLS 350 interstitial tank sensor

*Piping:* (TK # 5, 6, 7) - (Installing) Veeder Root TLS350 interstitial piping sump sensors, at all submersible sumps only (TK # 5, 6, 7) - (Installing) Veeder Root TLS350 electronic line leak detector

(f) Corrosion Protection being used:

*Tank:* (TK # 5, 6, 7) - (Installing) Composite *Piping:* (TK # 5, 6, 7) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

	<b>(7)</b>	PERSON.	FIRM	OR	COMPANY	PERFORMING	WORK:
--	------------	---------	------	----	---------	------------	-------

Contact Person: Kevin Krohn

Phone:

James of Coffey

Contractor Registration # Exp

Sincerely,

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)