

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

Amended

FOR OFFICE USE ONLY

Facility # 2-034834
Permit # 00954-2007INS
Request Rec'd 06/28/2007
Amended Date 08/08/2007
Approval Date 7/2/2007 JC
Permit Expires 1/2/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Delnor Community Hospital 300 Randall Rd Geneva, IL 60134	Delnor Community Hospital 300 Randall Rd Geneva, Kane Co., IL
Contact: Dave KelpsWolf (630) 208-4271	Contact: Dave Kelps (630) 208-4271

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 2) 20,000 gallons
- (b) Type of tanks: (TK # 2) (Installing) Glasteel II double wall composite
- (c) Type of piping: (TK # 2) (Installing) A.P.T. Poly Tech P100SC double wall flexible (see amendment contingencies), (TK # 2) (Installing) A.P.T. Poly Tech DCT-400 secondary chase piping.
- (d) Product to be stored in each tank: (TK # 2) Diesel Fuel
- (e) Type of leak detection being used:

Tank: (TK # 2) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge with CSLD, (TK # 2) - (Installing) Veeder Root TLS 350 Plus Interstitial tank sensor

Piping: (TK # 2) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensor at tank sump only, (TK # 2) - (Installing) American Suction

(f) Corrosion Protection being used:

Tank: (TK # 2) - (Installing) Composite

Piping: (TK # 2) - (Installing) Non-corrosive flexible

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

((7)	PERSON.	FIRM OR	COMPANY	PERFORM	ING WORK

Contact Person: Jan

Phone:

James of Coffey

Contractor Registration # Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

(Rev. - 1/98)

Fire Department Office Coordinator Division File