



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

**Amended**

FOR OFFICE USE ONLY  
Facility # 2-025475  
Permit # 00882-2007UPG  
Request Rec'd 06/14/2007  
**Amended Date 08/08/2007**  
Approval Date 6/22/2007 JC  
Permit Expires 12/22/2007

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |   |
|--|---|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br><br>Road Ranger, LLC<br>P.O. Box 4745<br>Rockford, IL 61110-4745<br><br>Contact: John Carabelli | <b>(2) FACILITY</b> - name and address where tanks are located:<br><br>Road Ranger #235<br>19 North 681, U.S. Highway 20<br>Hampshire, Kane Co., IL<br><br>Contact: John Carabelli (815) 387-1700 |
|--|---|

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 2, 3) - 10,000 gallons, (TK # 4, 5) - 20,000 gallons

(b) **Type of tanks:**

(c) **Type of piping:** (TK # 1, 2, 3) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass piping to replace existing piping from the four existing islands, and to accommodate the addition of four new islands (a piping removal permit will not be required since the new piping will be installed in the same piping trench as the old runs). Contractor notes that the only work that will be done over the top of the tanks (all five) is the removal of the concrete around the submersible tank sumps in order for them to lower the manholes so a new driveway can be installed in that location. **The existing vent piping for all five tanks will be re-routed also.**

(d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline, (TK # 4, 5) - Diesel Fuel (see contingencies for amendment information)

(e) **Type of leak detection being used:**

**Tank:**

**Piping:** (TK # 1, 2, 3) - Existing line leak detector to remain, (TK # 1, 2, 3) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at each gasoline submersible sump and at the two island sumps that are closest to the tanks / and new storm sewer run.

(f) **Corrosion Protection being used:**

**Tank:**

**Piping:**

(g) **Spill containment devices:**

(h) **Overfill prevention devices:**

(i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

|  |
|--|
| <b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b><br><br><br><br><br><br><br><br><br><br>Contact Person: Scott Sockness<br>Phone:<br><br>Contractor Registration #    Exp. |
|--|

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)