



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 6-016541  
Permit # 01187-2007INS  
Request Rec'd 08/03/2007  
Amended Date  
Approval Date 8/6/2007 JC  
Permit Expires 2/6/2008

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Road Ranger, LLC P.O. Box 4745 Rockford, IL 61110-4745  Contact: John Carabelli	<b>(2) FACILITY</b> - name and address where tanks are located:  Road Range #154 101 Piasa Lane Hartford, Madison Co., IL  Contact: Tom Parsons (618) 254-3548
--	--

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed:** (TK # 11, 12, 13) - 10,000 gallons, (TK # 14) - 20,000 gallons
- (b) Type of tanks:** (TK # 11, 12, 13, 14) - (Installing) Containment Solutions single wall fiberglass
- (c) Type of piping:** (TK # 11, 12, 13) - Existing fiberglass secondary containment from the two easternmost islands to the other four islands to remain, (TK # 11, 12, 13) - (Installing) new OPW Geoflex non-corrosive flexible piping from the new tanks to the two easternmost islands, and will then be tied into the existing product piping, (TK # 11, 12, 13) - Existing non-corrosive flexible within the existing secondary containment from the two easternmost islands to the other four islands to remain, (TK # 14) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass to replace all the existing.
- (d) Product to be stored in each tank:** (TK # 11, 12, 13) - Gasoline, (TK # 14) - Diesel Fuel
- (e) Type of leak detection being used:**
  - Tank:** (TK # 11, 12, 13, 14) - Existing automatic tank gauging (TLS 350 Plus with CSLD from the old tank system to be re-used for this new system).
  - Piping:** (TK # 11, 12, 13, 14) - (Installing) Red Jacket FX1DV mechanical line leak detector, (TK # 11, 12, 13, 14) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors at each submersible sump only.
- (f) Corrosion Protection being used:**
  - Tank:** (TK # 11, 12, 13, 14) - (Installing) Fiberglass
  - Piping:** (TK # 11, 12, 13) - (Installing) Non-corrosive flexible, (TK # 14) - (Installing) Fiberglass
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) GENERAL REQUIREMENTS:**

**(6) SPECIAL CONTINGENCIES:**

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>          Contact Person: Greg Phone:  Contractor Registration #    Exp.
--

Sincerely,

