



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

Amended

FOR OFFICE USE ONLY
Facility # 5-038551
Permit # 01035-2012UPG
Request Rec'd 10/02/2012
Amended Date 11/08/2012
Approval Date 10/3/2012 JC
Permit Expires 4/3/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Road Ranger, LLC P.O. Box 4745 Rockford, IL 61110 Contact: John Carabelli (815) 387-1700	(2) FACILITY - name and address where tanks are located: Road Ranger #266 700 King Road New Berlin, Sangamon Co., IL Contact: John Carabelli
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 12,000 gallons, (TK # 2) - 10,000 gallons, (TK # 3) - 8,000 gallons

(b) **Type of tanks:**

(c) **Type of piping:** (TK # 2) - (Installing) Transition Sumps FRP fiberglass located near the end dispenser that is closest to the existing store building, (TK # 2) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX from the new transition sump to the new blending shed sump only (see contingencies section and site plan).

(d) **Product to be stored in each tank:** (TK # 1, 3) - Gasoline, (TK # 2) - Diesel Fuel

(e) **Type of leak detection being used:**

Tank: (TK # 1, 2, 3) - (Installing) Automatic Tank Gauging Veeder Root TLS 450 with CSLD monitor and probes.

Piping: (TK # 2) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D, (TK # 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 at the new transition sump only (contractor states the line between the new transition sump and the submersible pump is existing double wall).

(f) **Corrosion Protection being used:**

Tank:

Piping: (TK # 2) - (Installing) Fiberglass Non-Corrosive

(g) **Spill containment devices, piping, and dispenser containment devices:**

(h) **Overfill prevention devices:**

(i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Quincy, IL 62305	Contact Person: Steve Disselhorst Phone: (217) 224-9725 Contractor Registration # Exp.
---	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File

