



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 3034333  
Permit # 00691-2022REM  
Request Rec'd 06/28/2022  
Amended Date  
Approval Date 6/28/2022 SB  
Permit Expires 12/28/2022

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Welcome Way Place, LLC 2704 69th Avenue Court Moline, IL 61265</p> <p>Contact: Sohan Gill (309) 762-4121</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Preet Mini Mart 2704 69th Ave. Court Moline, IL 61265</p> <p>Contact: Sohan Gill (309) 762-4121</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1, 2) - 10,000, (TK # 3) - 8,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Pipeco will be removing all existing Environ STP sumps along with the dispenser sumps and all the existing Environ double wall piping. We will be replacing it with new Franklin FRP STP single wall sumps and APT single wall dispenser sumps. We will be installing new APT 150XP double wall flexible piping. Forest Road Consulting will do all of the sampling off the soil.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Pipeco, Inc.  
610 29TH ST  
Bettendorf, IA 52722

Contact Person: Debbie Rindler  
Phone: (563) 344-0700  
Contractor Registration # IL2034 Exp. 9/28/2022

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist  
Division File