



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7007501
Permit # 00692-2022REM
Request Rec'd 06/28/2022
Amended Date
Approval Date 6/28/2022 SB
Permit Expires 12/28/2022

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821</p> <p>Contact: Landon Bayley (618) 382-2334 Ext. 248</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Hucks #51 I-57 & Highway 15 Mount Vernon, IL 62867</p> <p>Contact: Andrew Burk (618) 382-2334</p>
---	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1, 2, 3) - 10,000, (TK # 8, 9) - 20,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium, (TK # 3, 8, 9) - Diesel Fuel*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number: 2022-0564*
- (f) *Date each tank was last used: (TK # 1, 2, 3) - 3/10/2022, (TK # 8, 9) - Unknown*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES** : Pipeco will be removing all existing Environ STP sumps along with the dispenser sumps and all the existing Environ double wall piping. We will be replacing it with new Franklin FRP STP single wall sumps and APT single wall dispenser sumps. We will be installing new APT 150XP double wall flexible piping. Forest Road Consulting will do all of the sampling off the soil.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.
St. Louis, MO 63115

Contact Person: Terry Smith
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2024

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File