



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 3012728
 Permit # 00700-2022UPG
 Request Rec'd 06/29/2022
 Amended Date
 Approval Date 6/30/2022 SB
 Permit Expires 12/30/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>S & R Petroleum, Inc. 8th & Schuyler, Hwy 164 Oquawka, IL 61469</p> <p>Contact: Sean Chinna (319) 572-4667</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Phillips 66 8th & Schuyler, Highway 164 Oquawka, IL 61469</p> <p>Contact: Jackie Jones (309) 867-2445</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 8,200*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 5) - Gasoline - Regular, (TK # 6) - Gasoline - Premium, (TK # 7) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 5, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Performed an inspection to ensure that the ball float vent valves were compliant and found that the tanks did not have any form of an overfill device, only a straight drop tube; will be installing Franlin Fueling Defender drop tubes on tanks 5-7

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305</p>	<p>Contact Person: Marty Jackson Phone: (217) 223-2190 Contractor Registration # IL2021 Exp. 5/22/2024</p>
--	--

Sincerely,

Shelly Bradley

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File