



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3034333
Permit # 00708-2022UPG
Request Rec'd 06/28/2022
Amended Date
Approval Date 6/30/2022 SB
Permit Expires 12/30/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Welcome Way Place, LLC 2704 69th Avenue Court Moline, IL 61265</p> <p>Contact: Sohan Gill (309) 762-4121</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Preet Mini Mart 2704 69th Ave. Court Moline, IL 61265</p> <p>Contact: Sohan Gill (309) 762-4121</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000, (TK # 3) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC, (TK # 1, 2, 3) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium, (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1, 2, 3) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3) Spill Contain Device - Double Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 2) Overfill Prev Device - Ball Only Removed Ball Float Vent Valve*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Will be installing new FRP STP sumps; reusing the existing submersible pumps; replacing single wall spill buckets with new Franlin Fueling Defender Double wall spill buckets along with new Defender overfill drop tube valves. Also, removing all the existing piping (which exceeds 20 feet or 50% of the total pipe run) and will be installing new APT 150XP flexible double wall piping and dispenser sumps. Installing new non-discriminating sensors with positive shut down in each sump. Will be removing the ball from the cage on tank #2.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Pipeco, Inc.
610 29TH ST

Contact Person: Debbie Rindler
Phone: (563) 344-0700

Sincerely,

A handwritten signature in black ink that reads "Shelly Bradley". The signature is written in a cursive, slightly slanted style.

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File