



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 5044761
 Permit # 00737-2022UPG
 Request Rec'd 07/06/2022
 Amended Date
 Approval Date 7/8/2022 SB
 Permit Expires 1/10/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>GPM Investments, LLC 8565 Magellan Pkwy, Suite 400 Richmond, VA 23227</p> <p>Contact: Rolfe Lann (804) 730-1563</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Jiffi Stop #588 841 West Morton Ave. Jacksonville, IL 62650</p> <p>Contact: Rolfe Lann (804) 730-1568</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 5,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 5) - E-85*
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Removing vent ball float valve and aluminum drop tube in tank 5, Installing new EBW Defender OPV drop tube in place of for overfill protection. This OPV will be AGB rated for E-85 use

Blended fuel compatibility form for this facility has been submitted and approved on 7/6/22

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Pemco Service Company, Inc. 1040 East Second Street Gilman, IL 60938</p>	<p>Contact Person: William "Butch" VonDrehle Phone: (815) 265-7364 Contractor Registration # IL1224 Exp. 2/26/2024</p>

Sincerely,

A handwritten signature in black ink that reads "Shelly Bradley". The script is cursive and fluid, with the first name "Shelly" and last name "Bradley" written in a single line.

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File