



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 3000811
 Permit # 00745-2022REM
 Request Rec'd 07/11/2022
 Amended Date
 Approval Date 7/11/2022 SB
 Permit Expires 1/11/2023

Revised

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Blick & Blick Oil, Inc. 203 SE 5th Ave. Aledo, IL 61231</p> <p>Contact: Steve Blick (309) 582-2012</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Blick & Blick Oil, Inc. 203 SE 5th Ave. Aledo, IL 61231</p> <p>Contact: Steve Blick (309) 582-2012</p>
--	--

(3) REMOVAL OF TANKS:

- (a) *Number and size of tanks being removed: (TK # 2, 3, 4) - 6,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 2) - Diesel Fuel, (TK # 3) - Gasoline - Premium, (TK # 4) - Gasoline - Regular*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 2, 3, 4) - 6/14/2022*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Removal of the three noted tanks because of rain on Friday July 8th they floated out of the ground They were scheduled to be backfill in place but with them floating out they will need to be removed. The new piping runs across the top of these tanks and will need to be disconnected an reassemble after the removal.

Revision Reason: To eliminate duplicate tank id numbers

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Central Petroleum Equipment Company 109 Terrace Dr. Blue Grass, IA 52726</p>	<p>Contact Person: Roger Clark Phone: (563) 381-5092 Contractor Registration # IL345 Exp. 6/14/2024</p>

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist
 Division File