



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2043821
 Permit # 00761-2022UPG
 Request Rec'd 07/13/2022
 Amended Date
 Approval Date 7/13/2022 DS
 Permit Expires 1/13/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Harjit Sahi 1217 E. Cambridge Dr. Schererville, IN 46375</p> <p>Contact: Sandeep Sahi (219) 671-9937</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Go Lo 450 Cicero Avenue University Park, IL 60426</p> <p>Contact: Sandeep Sahi (708) 534-3050</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 10) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 10) Piping - Other Submersible Pump, (TK # 10) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 10) - E-85*
- (e) *Type of leak detection being used:*
 - Tank:** (TK # 10) *Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor*
 - Piping:** (TK # 10) *Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 10) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) *Corrosion Protection being used:*
 - Tank:**
 - Piping:**
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 10) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : This site was selling E85 and some of the fueling items were not E85 compatible. This permit application is to replace the items with parts compatible with E85 including tank and line leak detection, probe, overfill prevention and submersible pump.

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File