



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5029616  
Permit # 00763-2022UPG  
Request Rec'd 07/12/2022  
Amended Date  
Approval Date 7/17/2022 DS  
Permit Expires 1/19/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|   |  |
|---|--|
| <p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Illinois Secretary of State<br/>2701 South Dirksen Parkway<br/>Springfield, IL 62756</p> <p>Contact: Darrel Sexton (217) 782-9437</p> | <p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Capitol Building<br/>2nd &amp; Monroe St<br/>Springfield, IL 62756</p> <p>Contact: Tom Beatty (217) 782-9437</p> |
|---|--|

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 2,500*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Steel Single Wall Piping , (TK # 3) Piping - Aboveground*
- (d) *Product to be stored in each tank: (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**


On site contractor has damaged underground piping and repaired with copper. We would like to re-pipe these lines out of the top of the tank sump directly over to a concrete vault containment that leads straight down to the day tank.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

W J Scott Company  
3861 Tozer Road  
Springfield, IL 62707

Contact Person: Jim Scott  
Phone: (217) 787-6081  
Contractor Registration # IL1949 Exp. 4/18/2024

Sincerely,

---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File