



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 1018404  
Permit # 00777-2022UPG  
Request Rec'd 07/18/2022  
Amended Date  
Approval Date 7/18/2022 DS  
Permit Expires 1/18/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Stephenson Service Company P.O. Box 917 Freeport, IL 61032  Contact: Gordon Williams (815) 235-7400	<b>(2) FACILITY</b> - name and address where tanks are located:  Lena Fast Stop 519-1/2 E. Lena Street Lena, IL 61048  Contact: Deidre Wybourn (815) 369-2100
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 5) Piping - Flexible Double Wall A.P.T. Poly Tech*

(d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

The satellite line from dispenser number 6 appears to have a leak on the primary. No release is evident as this site had double wall piping and sumps.

We are going to remove the failed line and install new 1.5" APT piping in its place.

NOV on tank 4 is in the process of being completed.

**NOTE: UDC's must be installed as well as sump sensors with positive shut down if not already existing**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


Oil Equipment Company, Inc.

Contact Person: TJ Winkler

4701 Lien Road  
Madison, WI 53704

Phone: (608) 249-2881  
Contractor Registration # IL1318 Exp. 11/13/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File