



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 7007501
 Permit # 00705-2022ABN
 Request Rec'd 06/27/2022
 Amended Date 07/19/2022 DS
 Approval Date 6/30/2022 SB
 Permit Expires 12/30/2022

Amended

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821</p> <p>Contact: Landon Bayley (618) 382-2334 Ext. 248</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Hucks #51 I-57 & Highway 15 Mount Vernon, IL 62867</p> <p>Contact: Andrew Burk (618) 382-2334</p>
---	--

(3) **ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned: (TK # 6) - 20,000*
- (b) *Product stored in each tank: (TK # 6) - Diesel Fuel*
- (c) *Location of tanks being abandoned: CONTAMINATED SITE! IEMA Number: 2022-0564*
- (d) *Location of piping being abandoned:*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES :**

Amendment Reason: We will be using pea gravel to fill the tank rather than flowable fill as indicated on the application. Per Travis Smith, there is some old piping running across active piping that we can abandon rather than exposing the active piping

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>UPC Enterprises, LC d/b/a United Petroleum Service 4444 Union Blvd. St. Louis, MO 63115</p>	<p>Contact Person: Terry Smith Phone: (314) 241-3767 Contractor Registration # IL002402 Exp. 2/10/2024</p>

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist
 Division File