



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453162

FOR OFFICE USE ONLY

Facility # 2022735
Permit # 00831-2022UPG
Request Rec'd 08/01/2022
Amended Date
Approval Date 8/2/2022
Permit Expires 2/2/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ghulam Qadir 6939 North Keating Lincolnwood, IL 60712 Contact: Ghulam Qadir (773) 671-0427	(2) FACILITY - name and address where tanks are located: Shell 9955-8 South Western Avenue Chicago, IL 60643 Contact: Ghulam Qadir (773) 779-2881
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 12,000, (TK # 6, 7) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6, 7) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L , (TK # 5, 6, 7) Piping - Shear Valves , (TK # 5, 6, 7) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 5) - Gasoline - Regular, (TK # 6) - Gasoline - Premium, (TK # 7) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,

Seán Keane

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File