



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 6039907
Permit # 00704-2022UPG
Request Rec'd 06/16/2022
Amended Date 08/04/2022 DS
Approval Date 6/30/2022 SB
Permit Expires 12/30/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: QuikTrip Corporation 4705 South 129th East Ave. Tulsa, OK 74134 Contact: Laura Thompson (918) 615-7304	(2) FACILITY - name and address where tanks are located: QuikTrip #695 605 West Bethalto Drive Bethalto, IL 62010 Contact: Mike Conner (636) 916-0937
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 20,000, (TK # 3) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping Ameron 4000 L single wall vent, (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: We need to change the vent location-See updated drawings NEEDING TO CHANGE ALL VAPOR BUCKETS TO OPW 1SC-EDGE SINGLE WALL. CHANGE ALL FILL BUCKETS TO OPW DW W/VISUALLY GAUGE 1SC-3112D CHANGING ALL OVERFILL WITH NEW OPW 71SP DROP TUBES NEED TO AMEND TO UPGRADE PERMIT

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,

A handwritten signature in dark ink that reads "Shelly Bradley". The script is cursive and fluid, with the first name "Shelly" and last name "Bradley" clearly legible.

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File