



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2042094
Permit # 00845-2022UPG
Request Rec'd 08/04/2022
Amended Date
Approval Date 8/4/2022 DS
Permit Expires 2/6/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101 Contact: Thomas Roy (610) 625-8061	(2) FACILITY - name and address where tanks are located: Flossmoor - IL0027 3950 Vollmer Road Flossmoor, IL 60422 Contact: Tammy Hessler (610) 625-8086
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000, (TK # 2) - 15,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Galvanized Steel Single Wall Piping , (TK # 1, 2) Piping - Ball Valves , (TK # 1, 2) Piping - Shear Valves*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The existing dispensers to be removed currently wrap around the existing canopy columns. Five new dispensers will be installed adjacent to the existing canopy columns over the piping sumps on the same islands. The outside row of dispensers will be removed with piping and electrical secured so plates can be placed over the existing island openings. All piping adjustments will be made with galvanized steel pipe within the existing piping sumps.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


B & K Equipment Company

Contact Person: Ed Angell

2939 175th Street
Lansing, IL 60438

Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File