



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4008047
Permit # 00882-2022UPG
Request Rec'd 08/12/2022
Amended Date
Approval Date 8/12/2022 DS
Permit Expires 8/24/2022

Permit for Emergency Repair Request on 8/11/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Wortman-Meyer Properties, LLC 1502 W. Fayette Effingham, IL 62401</p> <p>Contact: Lisa Wortman (217) 342-7291</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Holiday Jack Flash 1502 West Fayette Avenue Effingham, IL 62401</p> <p>Contact: Lisa Wortman (217) 342-4043</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 7) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 7) Piping - Flex Connector Steel*

(d) *Product to be stored in each tank: (TK # 7) - Gasoline - Regular*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

OPENED UP SUMP AND FOUND FUEL IN SUMP BUT NOTHING FOUND WET ON PIPING. TURNED ON BREAKER FOR STP AND TO RUN 3.0 TEST FOUND LINE WAS STILL AT 18.568 PSI RAN TEST AND LINE SETTLED TO 21-20 PSI WENT TO SUMP AND CHECKED FOR LEAKS OBSERVED FOR 15 MIN FOUND NOTHING CHECKED CONSOLE AND LINE WAS AT 20.883 TO 21.172 . WENT BACK TO SUMP AND STILL FOUND NOTHING WET. CUT OF THE LABEL ON FLEXLINE AND WIPED FLEX WITH HAND AND FOUND IT MOIST AROUND THE MIDDLE OF THE FLEX. SHUT OFF BRAKER AND CLOSED BALL VALVE. LOOKED ON TRUCK AND FOUND A 2X12" FLEXLINE REMOVED EXISTING FLEXLINE AND INSTALLED NEW FLEXLINE. PURGED RUL LINE . RAN 3.0 TEST ON CONSOLE BUT WAS ABLE TO MANUALLY START A .1 TEST SOFTWARE TO OLD. CONTACTED OWNER LISA WORTMAN AS PER HER REQUEST TO HAVE HER SCHEDULE A PRESION LINE TEST. AS PER TRAVIS BEFORE WE CAN OPEN LINE BACK UP. I LEFT MOTOR ON AND SHUT OFF ALL RUL SHEAR VALVES TO ALLOW CONSOLE TO RUN TESTS ON AUTO.

1 – SEQ# 6938 2 X 12 STAINLESS STEEL FLEXLINE

2 – SEQ# 5542 17 X 18 SORBENT PAD

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File