



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2027155
Permit # 00889-2022INS
Request Rec'd 08/14/2022
Amended Date
Approval Date 8/15/2022 DS
Permit Expires 2/15/2023

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061</p> <p>Contact: John Graham (847) 837-0777</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Forest View BP (GEI-164) 4701 S. Central Avenue Forest View, IL 60638</p> <p>Contact: Meghan Fitzpatrick (847) 837-0777</p>
---	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 14, 15) - 30,000*
- (b) Type of tank(s): (TK # 14, 15) Tank - Fiberglass Double Wall Containment Solutions*
- (c) Type of piping: (TK # 14, 15) Piping - Flexible Double Wall NUPI Smartflex from tanks to dispensers as well as for the remote fills, (TK # 14, 15) Piping - Other Submersible Pump, (TK # 14, 15) Piping - Extractor Fitting Valves, (TK # 14, 15) Piping - Shear Valves, (TK # 14, 15) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 14, 15) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 14, 15) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus, (TK # 14, 15) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors*
 - Piping: (TK # 14, 15) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 14, 15) Leak Detect - Piping - Discriminating Sump Sensor with positive shutdown in submersible, dispenser and remote fill sumps (if remote fills are more than 20')*
- (f) Corrosion Protection being used:*
 - Tank: (TK # 14, 15) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
 - Piping: (TK # 14, 15) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 14, 15) Spill Contain Device - Double Wall Spill Bucket Remote Fill*
- (h) Overfill prevention devices: (TK # 14, 15) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 14, 15) Overfill Prev Device - Overfill Alarm*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) GENERAL REQUIREMENTS : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) **SPECIAL CONTINGENCIES** :

Installing (2) 30,000 gallon DWFRP tanks (Diesel) and (1) 10,000 gallon DWFRP tank (DEF) along with new DW Semi-Rigid Nupi piping to (9) new dispenser islands w/ Nupi HDPE dispenser sumps, new DW Semi-Rigid remote fill piping and SW Semi-Rigid vent piping as shown on plan.


NOTES: A motor fuel dispensing permit must be applied for asap. A DEF tank is also being installed, please see drawing.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File