



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4047488
Permit # 00998-2022REM
Request Rec'd 09/15/2022
Amended Date
Approval Date 9/15/2022 DS
Permit Expires 3/15/2023

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>City of Champaign 702 Edgebrook Drive Champaign, IL 61820</p> <p>Contact: Tom Schuh (217) 403-4710</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>City of Champaign Right-of-Way 3103 Ridgewood Drive Champaign, IL 61820</p> <p>Contact: Nathan Dornfeld (217) 403-4700</p>
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1) - 500*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1) - Heating Oil*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1) - 12/31/1973*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

Any remaining water/product will be pumped out of the tank and into DOT-approved 55-gallon drums. This material will be hauled off to a treatment facility. The tank will be freed of vapor to eliminate the explosion/fire potential. After the atmosphere in the tank is rendered safe, and with approval of the on-site OSFM STSS, the tank will then be removed from the ground. The tank will be cut and cleaned and then sent for recycling/disposal. The excavation will be backfilled to approximately one foot below grade with flowable fill, per the City of Champaign's request (due to the excavation being beneath a sidewalk). Excavated soils will be hauled to a properly permitted landfill.

CSD Environmental Services, Inc. personnel will be onsite to provide removal oversight and documentation including soil samples. Samples will consist of four sidewall samples and one floor sample. Samples will be sent to Teklab, Inc. for analysis of BTEX and PNAs (in accordance with 35 IAC Part 734). Removal and sampling efforts will be summarized in a site assessment report to be supplied to the OSFM upon completion. Photos of the removal activities as well as a site map showing sample locations will be included within the report.

NOTE: Any associated piping must be removed as well

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

CSD Environmental Services, Inc.
2220 Yale Boulevard
Springfield, IL 62703

Contact Person: Frank Pinkley
Phone: (217) 522-4085
Contractor Registration # IL002230 Exp. 3/17/2024

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File