



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2009881
Permit # 01016-2022UPG
Request Rec'd 09/19/2022
Amended Date
Approval Date 9/19/2022 DS
Permit Expires 3/21/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Irving Gasmart, Inc. 38 E. Irving Park Road Roselle, IL 60172 Contact: Rajeev Korah (224) 766-9046	(2) FACILITY - name and address where tanks are located: Marathon Gas Station 38 E. Irving Park Road Roselle, IL 60172 Contact: Nizar Bhayani (224) 766-9046
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2, 3) - 7,500*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall Universal Petro Pipe from existing tanks to new dispensers as shown in site plan, (TK # 1, 2, 3) Piping - Other Steel Riser, (TK # 1, 2, 3) Piping - Other Submersible Pump, (TK # 1, 2, 3) Piping - Extractor Fitting Valves, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Flex Connector Steel, (TK # 1, 2, 3) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Premium, (TK # 2, 3) - Gasoline - Regular*
- (e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2, 3) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps
- (f) *Corrosion Protection being used:*

Tank:

Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2, 3) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Contractor is re-piping the station and also installing new overfill and spill prevention as well as all new STP and dispenser sumps.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


America Petropump Services LLC d/b/a Ampsco Services

Contact Person: Ravindra Penmatsa

4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Phone: (312) 286-6722
Contractor Registration # IL002420 Exp. 5/22/2023

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", written in dark ink. The signature is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File