



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 6043328
Permit # 00639-2022UPG
Request Rec'd 06/14/2022
Amended Date 09/20/2022 DS
Approval Date 6/14/2022 DS
Permit Expires 12/14/2022

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: BNP Group, Inc. 904 Spyglass Hill Court Caseyville, IL 62232 Contact: Bobby Patel (609) 325-1027	(2) FACILITY - name and address where tanks are located: Countryside Corner 17937 Rt. 177 Nashville, IL 62263 Contact: Raj Patel (708) 789-3903
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 15,000, (TK # 2) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Steel Single Wall Piping , (TK # 1, 2) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC , (TK # 1, 2) Piping - Ball Valves , (TK # 1, 2) Piping - Shear Valves , (TK # 1, 2) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1, 2) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 2) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The site failed a tank and product line test. We believe the spill bucket is the cause of the tank test failure. The Prem product line also failed. We will replace the entire Premium product line and the UL product line. New FRP single wall dispenser sumps will be installed. The STP sumps will remain and STP sump sensors will be added. The existing line leak detectors and dispenser sump sensors will remain.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


Amendment Reason: Owner wants to install now UL product line also. Need to remove ball floats on the Premium tank and replace with overfill.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.
St. Louis, MO 63115

Contact Person: Terry Smith
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File