



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6014659  
Permit # 01033-2022UPG  
Request Rec'd 09/21/2022  
Amended Date  
Approval Date 9/21/2022 DS  
Permit Expires 3/21/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|                                                                                                                                                                                                               |                                                                                                                                                                                               |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:<br><br>First Student, Inc.<br>600 Vine Street, Suite 1400<br>Cincinnati, OH 45202<br><br>Contact: Brian Willis (513) 419-8639 | <b>(2) FACILITY</b> - name and address where tanks are located:<br><br>First Student, Inc. #20293<br>17 Commercial Court<br>Glen Carbon, IL 62034<br><br>Contact: Brian Willis (618) 692-4290 |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Steel Single Wall Piping , (TK # 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tank to dispensers as shown in site drawing, (TK # 3) Piping - Other Steel Riser, (TK # 3) Piping - Ball Valves , (TK # 3) Piping - Shear Valves , (TK # 3) Piping - Flex Connector Steel, (TK # 3) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*  
  
*Tank:*  
  
*Piping: (TK # 3) Leak Detect - Piping - European with No Test Req Suction , (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor in submersible and dispenser sumps*
- (f) *Corrosion Protection being used:*  
  
*Tank:*  
  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 3) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 3) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Installing new tank top piping sump, new fiberglass double wall product piping, new spill bucket and overfill drop tube, new steel riser pipes. Dispenser sump sensors will be added. Piping will be european suction.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


UPC Enterprises, LC d/b/a United Petroleum Service

Contact Person: Terry Smith

4444 Union Blvd.  
St. Louis, MO 63115

Phone: (314) 241-3767  
Contractor Registration # IL002402 Exp. 2/10/2024

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File