



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2011488
 Permit # 01319-2021UPG
 Request Rec'd 11/12/2021
 Amended Date
 Approval Date 11/15/2021 DS
 Permit Expires 5/17/2023

Extended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Power Mart Corporation 572 W. Lake St. Elmhurst, IL 60126</p> <p>Contact: Samer Odeh (630) 816-3534</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Power Mart Company Operations - Palos Heights #1, LLC 6400 W. 127th St. Palos Heights, IL 60463</p> <p>Contact: Robert or Miguel (630) 816-3534</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Flexible Double Wall A.P.T. Poly Tech XP 1500 , (TK # 6) Piping - Shear Valves , (TK # 6) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 6) - E-85*
- (e) Type of leak detection being used:*
 Tank:
 Piping:
- (f) Corrosion Protection being used:*
 Tank:
 Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


Installing new flexible double wall pipe to bring E-85 from dispenser #1/2 to all other (3) dispensers.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

NOTE: Site has existing sensors

<u>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</u>	
B & K Equipment Company 2939 175th Street	Contact Person: Ed Angell Phone: (708) 474-3344

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File