



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6040475
Permit # 01065-2022UPG
Request Rec'd 09/27/2022
Amended Date
Approval Date 9/28/2022 DS
Permit Expires 3/28/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Knapp Oil Company, Inc. P.O. Box 215 Xenia, IL 62899</p> <p>Contact: Nicholas Knapp (618) 678-2211</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Nashville Citgo 17970 Mockingbird Road Nashville, IL 62263</p> <p>Contact: Patricia Bailey (618) 678-2211</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000, (TK # 4) - 15,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 4) Piping - Flexible Double Wall Environ Geo Flex*

(d) *Product to be stored in each tank: (TK # 1) - B-11, (TK # 4) - B-20*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

At the diesel transition sump, disconnect the Environ product line on the side that runs to dispensers 13 to 18A. Plug the pipe where the Environ product line was removed. This will stop all product flow to dispensers 13 to 18A. The diesel tanks will still feed dispensers 10 to 12A. The remaining line will be tested.


NOTE: A separate removal permit is to be taken out to remove the piping and dispensers that will no longer be used

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Mid-South Steel Products, Inc.
2071 Corporate Circle Drive PO Box 277
Cape Girardeau, MO 63703

Contact Person: Billy Thorne
Phone: (573) 335-5529
Contractor Registration # IL1194 Exp. 8/17/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File