



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2009898
Permit # 01085-2022UPG
Request Rec'd 09/30/2022
Amended Date
Approval Date 10/3/2022 DS
Permit Expires 4/4/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ahmad Zahdan 12345 S. Keeler Ave. Alsip, IL 60803 Contact: Ahmad Zahdan (708) 372-7632	(2) FACILITY - name and address where tanks are located: Gas on St. Charles 833 E. St. Charles Road Lombard, IL 60148 Contact: Ahmad Zahdan (708) 372-7632
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 7,500*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Other Steel Riser, (TK # 2) Piping - Other Submersible Pump, (TK # 2) Piping - Ball Valves, (TK # 2) Piping - Shear Valves, (TK # 2) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 2) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 2) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Tank #2 will be converted to E85 product. The other items changed to be compatible are the submersible pump, mechanical line leak detector, overfill drop tube, tank probe, shear valve, ball valve and pump flex connector within the pump sump.


NOTE: A blended fuel compatibility form will need to be completed

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File