



City of Chicago  
 Department of Public Health  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 3127453162

**FOR OFFICE USE ONLY**  
 Facility # 2017222  
 Permit # 01100-2022UPG  
 Request Rec'd 10/04/2022  
 Amended Date  
 Approval Date 10/5/2022  
 Permit Expires 4/5/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>AZ SPE, LLC          12345 S. Keeler Ave.          Alsip, IL 60803</p> <p>Contact: Ahmad Zahdan (708) 372-7632</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Amstar          4701 S. Western Blvd.          Chicago, IL 60609</p> <p>Contact: Khader Zahdan (708) 372-6732</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L , (TK # 5) Piping - Other Steel Riser, (TK # 5) Piping - Other Submersible Pump, (TK # 5) Piping - Ball Valves , (TK # 5) Piping - Shear Valves , (TK # 5) Piping - Flex Connector Steel, (TK # 5) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 5) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 5) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

<p><b>(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b></p>	
<p>B &amp; K Equipment Company          2939 175th Street          Lansing, IL 60438</p>	<p>Contact Person: Ed Angell          Phone: (708) 474-3344          Contractor Registration # IL1207 Exp. 2/14/2024</p>

Sincerely,

Seán Keane

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File