



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 2029371
 Permit # 00909-2022UPG
 Request Rec'd 08/19/2022
 Amended Date 10/06/2022 DS
 Approval Date 8/22/2022 DS
 Permit Expires 2/22/2023

Amended

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Petroliance, LLC 739 N. State Street Elgin, IL 60123</p> <p>Contact: Robert Crowe (847) 878-0483</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Petroliance, LLC 4019 W. Main Street McHenry, IL 60050</p> <p>Contact: Casey Mangum (847) 608-7155</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1) Piping - Galvanized Steel Single Wall Piping , (TK # 1) Piping - Flexible Double Wall A.P.T. Poly Tech, from tank to dispensers(TK # 1) Piping - Ball Valves , (TK # 1) Piping - Shear Valves , (TK # 1) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing (2) new fibergalss UDC sumps at island (same location as existing. Installing new APT flexible double wall piping from existing submersible and existing STP sump to new UDC's. Installing new sensors at UDC's and STP sumps with positive shut off. Replacing existing over spill containment manhole with new. Installing new shear valves and flexes at UDC's. Installing new ball valve at existing STP.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Amendment Reason: Repiping insteadf of repairing line in sump.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Howard Lee & Sons Inc.
4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Contact Person: Vicky Buhl
Phone: (815) 332-4966
Contractor Registration # IL456 Exp. 3/20/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File