



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 6040475  
 Permit # 01138-2022UPG  
 Request Rec'd 10/05/2022  
 Amended Date  
 Approval Date 10/13/2022 DS  
 Permit Expires 4/13/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Knapp Oil Company, Inc.        P.O. Box 215        Xenia, IL 62899</p> <p>Contact: Nicholas Knapp (618) 678-2211</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Nashville Citgo        17970 Mockingbird Road        Nashville, IL 62263</p> <p>Contact: Patricia Bailey (618) 678-2211</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000, (TK # 2) - 16,000, (TK # 3) - 4,000, (TK # 4) - 15,000, (TK # 5) - 5,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3, 4, 5) Piping - Flexible Double Wall OmegaFlex DoubleTrac , (TK # 1, 2, 3, 4, 5) Piping - Single Wall STP/Tanktop Sump , (TK # 2, 3, 4, 5) Piping - Shear Valves , (TK # 2, 3, 5) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1) - B-11, (TK # 2) - Gasoline - Regular, (TK # 3) - Kerosene, (TK # 4) - B-20, (TK # 5) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Removing tank sumps, dispensers sumps and islands. Installing new tank sumps and dispenser sumps, installing new product lines. Re-installing recently installed ovation 2 dispensers back on the islands. Public Diesel will have new ovation 2 highspeed dispensers, private will have existing Wayne select dispensers. Kerosene dispenser will be set back on the island. I have attached a detailed Quote with scope of work and drawing.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


**NOTES: Site has existing sump sensors with positive shut down. A removal permit must be obtained for the piping if one hasn't already.**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Mid-South Steel Products, Inc.  
2071 Corporate Circle Drive PO Box 277  
Cape Girardeau, MO 63703

Contact Person: Billy Thorne  
Phone: (573) 335-5529  
Contractor Registration # IL1194 Exp. 8/17/2024

Sincerely,



Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File