



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

## Extended

### FOR OFFICE USE ONLY

Facility # 2043256  
Permit # 00459-2022UPG  
Request Rec'd 04/26/2022  
Amended Date  
Approval Date 5/2/2022 DS  
Permit Expires 5/2/2023

### Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Rental Systems L.L.C. 1141 East Main Street, Suite 100 East Dundee, IL 60118  Contact: Kurt Kresmery (847) 428-1000	<b>(2) FACILITY</b> - name and address where tanks are located:  Glogovsky Oil Company III, Inc. dba East Dundee Shell 1097 E. Main Street East Dundee, IL 60118  Contact: Jeff Glogovsky (847) 276-0310
--	--

### **(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 5,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 4) Piping - Shear Valves , (TK # 4) Piping - Flex Connector Steel, (TK # 4) Piping - Single Wall Transition Sump*
- (d) *Product to be stored in each tank: (TK # 4) - E-85*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 4) Leak Detect - Piping - Non-Discriminating Sump Sensor*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Breaking out the (2) existing E85 dispenser islands, replacing the (2) existing dispenser sumps, impacts, liquid sensors and flex connectors with total E85 compatible components, then replacing concrete islands and re-setting the existing dispensers. The existing DWFRP piping to be revised only as required to renter new dispenser sumps.

### **(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Contact Person: Tim Berg  
Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 12/8/2022

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File