



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2009056
Permit # 00901-2022UPG
Request Rec'd 08/16/2022
Amended Date 10/24/2022 DS
Approval Date 8/17/2022 DS
Permit Expires 2/17/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: GMAK, LLC 6045 N. Campbell Ave. Chicago, IL 60645 Contact: Mehboob Khan (630) 300-8415	(2) FACILITY - name and address where tanks are located: Mobil 710 N. Wolf Road Des Plaines, IL 60016 Contact: Mehboob Khan (630) 300-8115
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5, 6) - 10,000, (TK # 7) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6, 7) Piping - Fiberglass Single Wall Piping Ameron , (TK # 5) Piping - Ball Valves , (TK # 5, 6, 7) Piping - Shear Valves , (TK # 5, 6, 7) Piping - Flex Connector Steel, (TK # 5) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel, (TK # 6) - Gasoline - Premium, (TK # 7) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 5) Leak Detect - Piping - Electronic Pressurized Line Leak Detection*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 7) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Convert tank 5 to Diesel. Remove islands and install new Bravo UDC. 3' of partial piping to accommodate new UDC New shear valves and flex connectors. This will correct several of the NOV violations. Install U bollards for collision protection.

Install new tank sump on tank 5 along with the ball valve and flex connector.

Install new spill container and drop tube on tank 7 RUL.

Amendment Reason: Upon testing the line we found a bad flex at the STP. We have to add a containment sump in order to replace the flex.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Hoyt Ary
Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 5/21/2024

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File