



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453162

FOR OFFICE USE ONLY

Facility # 2022764
Permit # 01176-2022UPG
Request Rec'd 10/25/2022
Amended Date
Approval Date 10/25/2022
Permit Expires 4/25/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Jeny Corp 7550 N. Sherican Chicago, IL 60626 Contact: Jose Pinarkyil (847) 832-1902	(2) FACILITY - name and address where tanks are located: (Mobil) Leah Mol, Inc. 7550 North Sheridan Leah Mol, Inc. (Operator) Chicago, IL 60626 Contact: Mathai Pinarkyil (773) 465-3450
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 10,000, (TK # 6) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 4) - Diesel Fuel, (TK # 6) - Gasoline - Regular*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices: (TK # 4, 6) Spill Contain Device - Double Wall Spill Bucket*

(h) *Overfill prevention devices: (TK # 4, 6) Overfill Prev Device - Overfill Drop Tube Valve*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> CAT Builders USA, Inc. 522 E. Dundee Road Palatine, IL 60074		Contact Person: Jan kopytek Phone: (630) 670-6280 Contractor Registration # IL002381 Exp. 5/6/2024
---	--	---

Sincerely,

Seán Keane

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File