



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 4002735
 Permit # 01193-2022UPG
 Request Rec'd 10/28/2022
 Amended Date
 Approval Date 10/31/2022 DS
 Permit Expires 5/2/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Macon County Highway Dept. 2405 N. Woodford Street Decatur, IL 62526</p> <p>Contact: Mark Funk (217) 424-1480</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Macon County Highway Dept 2405 N Woodford St. Decatur, IL 62526</p> <p>Contact: Kathy Gerhold (217) 424-1480</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L , (TK # 5) Piping - Ball Valves , (TK # 5) Piping - Shear Valves , (TK # 5) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 5) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 5) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Installing a new 18' x 20' two column Canopy , APT poly SW Dispenser Sump, Flex Connector & OPW Double Poppet Sheer Valve, Partial 3"x2" DW3000L Dual Alloy Ameron FRP Piping , New Ball Valve , A Gasboy Atlas Mechanical Dispenser & a PV 200 Island Terminal, Poured Concrete Sloped Island. Veeder Root Sump Sensor & Sensor Board. Removing the existing island & Partial piping

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313</p>	<p>Contact Person: Glen Davis Phone: (816) 761-1270 Contractor Registration # IL598 Exp. 2/23/2024</p>
---	--

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File