



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4002735  
Permit # 01194-2022REM  
Request Rec'd 10/28/2022  
Amended Date  
Approval Date 10/31/2022 DS  
Permit Expires 5/2/2023

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Macon County Highway Dept. 2405 N. Woodford Street Decatur, IL 62526</p> <p>Contact: Mark Funk (217) 424-1480</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Macon County Highway Dept 2405 N Woodford St. Decatur, IL 62526</p> <p>Contact: Kathy Gerhold (217) 424-1480</p>
---	--

**(3) REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 5) - 10,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Removing the existing island , dispenser, dispenser sump & approximately 18' of DW 3"x2" 3000L FRP DW Ameron Piping. Installing new island Sump & Partial piping

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Contact Person: Glen Davis  
Phone: (816) 761-1270  
Contractor Registration # IL598 Exp. 2/23/2024

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File