

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 2177851020

FOR OFFICE USE ONLY

Facility # 2004983 Permit # 01206-2022INS Request Rec'd 10/31/2022 Amended Date Approval Date 10/31/2022 DS Permit Expires 5/2/2023

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business

entity:

Village of Wheeling 77 W. Hintz Rd. Wheeling, IL 60090

Contact: Lana Rudnick (847) 229-4600

(2) **FACILITY** - name and address where tanks are located:

N Receiving Resvr&Pumnping St Northgate Pkwy & Lake Cook Rd Wheeling, IL 60090

Contact: Isac Santos (708) 459-2950

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 2) 1,000
- (b) Type of tank(s): (TK # 2) Tank Composite Double Wall Lannon
- (c) Type of piping: (TK # 2) Piping Flexible Double Wall A.P.T. Poly Tech P100SC, (TK # 2) Piping Other Steel Riser, (TK # 2) Piping Ball Valves, (TK # 2) Piping Extractor Fitting Valves, (TK # 2) Piping Single Wall STP/Tanktop Sump, (TK # 2) Piping Single Wall Transition Sump
- (d) Product to be stored in each tank: (TK # 2) Diesel Fuel
- (e) Type of leak detection being used:

Tank: (TK # 2) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus, (TK # 2) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Piping: (TK # 2) Leak Detect - Piping - European with No Test Req Suction

(f) Corrosion Protection being used:

Tank: (TK # 2) Corrosion Prot - Tank - Composite Non-Corrosive

Piping: (TK # 2) Corrosion Prot - Piping - Flexible Non-Corrosive

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 2) Spill Contain Device Single Wall Spill Bucket
- (h) Overfill prevention devices: (TK # 2) Overfill Prev Device Overfill Alarm
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.govor by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES:

This install is for a generator Install composite 1,000 gallon double wall tank from Lannon Install 2 monitoring wells install tank top piping sump and transition sump at the building
Install double walled APT 1" double wall piping to be European Suction
Install single wall fiberglass vent piping with steel riser above ground
Install Veeder Root TLS 450 Plus with in tank probe for level monitoring and tank interstice sensor for tank leak detection
Install Veeder Root overfill alarm with acknowledgment
Install single wall below grade EBW spill bucket

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group Contact Person: Robert Stenstrom

2422 Center Street Phone: (815) 398-6250

Rockford, IL 61108 Contractor Registration # IL1890 Exp. 4/12/2024

Sincerely,

Daniel Starks

Daniel J. Starke

cc: Storage Tank Safety Specialist Division File