



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2012719
Permit # 01219-2022UPG
Request Rec'd 10/19/2022
Amended Date
Approval Date 11/3/2022 DS
Permit Expires 5/3/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: AZ SPE, LLC 12345 S. Keeler Ave. Alsip, IL 60803 Contact: Ahmad Zahdan (708) 372-7632	(2) FACILITY - name and address where tanks are located: Citgo 5946 W. 26th Street Cicero, IL 60804 Contact: Mohameden Ahmed (708) 372-6732
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L , (TK # 2) Piping - Other Steel Riser, (TK # 2) Piping - Other Submersible Pump, (TK # 2) Piping - Ball Valves , (TK # 2) Piping - Shear Valves , (TK # 2) Piping - Flex Connector Steel, (TK # 2) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 2) - E-85*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 2) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices: (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*


- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : A portion of dispenser island #7/8 will be broke out to install a new single wall disepnsr sump. The island will be replaced. The existing dispenser #7/8 will be replaced with a dispenser compatible with E85 product. The tank pump sump will be replaced with a single wall sump. The submersible pump will be replaced with a pump compatible with E85 product. The sumps will be piped with single walled fiberglass and connected to the existing single wall fiberglass pipe. The probe will also be changed. An E85 compatibility form and tank change notification have been previously submitted for tank #2.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street

Contact Person: Ed Angell
Phone: (708) 474-3344

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File