



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 7-043712
Permit # 01135-2007INS
Request Rec'd 07/27/2007
Amended Date
Approval Date 7/30/2007 JC
Permit Expires 1/30/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Pilot Travel Centers LLC 5508 Lonas Drive Knoxville, TN 37939-0146 Contact: Patrick Deptule	(2) FACILITY - name and address where tanks are located: Pilot Travel Center #482 Intersection of Rt. 15 & Davidson Avenue Mount Vernon, Jefferson Co., IL Contact: Aaron Dickerson (865) 588-7488 Ext. 2022
---	---

(3) INSTALLATION OF TANKS:

(a) Number and size of tanks being installed: (TK # 1, 2, 3, 4, 5) - 20,000 gallons, (TK # 6) - 12,000 gallons, (TK # 7) - 8,000 gallons

(b) Type of tanks: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Highland Tank Titan Jacketed double wall steel

(c) Type of piping: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Ameron Dualoy 3000/LCX double wall fiberglass (including a siphon bar between tanks 1,2,3).

(d) Product to be stored in each tank: (TK # 1, 2, 3, 7) - Diesel Fuel, (TK # 4) - Bio-Diesel, (TK # 5, 6) - Gasoline

(e) Type of leak detection being used:

Tank: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Veeder Root TLS 350 Plus Interstitial tank sensor, (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Veeder Root TLS 350 Plus Automatic tank gauge (for inventory purposes only).

Piping: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Veeder Root TLS 350 Plus interstitial piping sump sensors at all tank sumps, all dispenser sumps, and at the blending pump sump, (TK # 1, 3) - (Installing) FE Petro STP-MLD-HCD mechanical line leak detector, (TK # 5, 6) - (Installing) FE Petro STP-MLD mechanical line leak detector, (TK # 7) - (Installing) FE Petro STP-MLD-D mechanical line leak detector. (The line for tank #4 will be suction - see site plan for location of blending pump sump. There will be interstitial sensors at tank #4 tank sump and at the blending sump).

(f) Corrosion Protection being used:

Tank: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Composite

Piping: (TK # 1, 2, 3, 4, 5, 6, 7) - (Installing) Fiberglass

(g) Spill containment devices:

(h) Overfill prevention devices:

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Mick Cronister or Chuck Hoenig Phone: Contractor Registration # Exp.

Sincerely,

