



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 6-024449
Permit # 01125-2007LIN
Request Rec'd 07/27/2007
Amended Date
Approval Date 7/27/2007 JC
Permit Expires 1/27/2008

**Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances.**

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Part 170. Such inspections of interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Gateway FS, Inc.        221 E. Pine Street, P.O. Box 100        Red Bud, IL 62278</p> <p>Contact: Jeff Gillespie (618) 282-4000</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Gateway Fs Inc        509-511 Park St        Waterloo, Monroe Co., IL</p> <p>Contact: Smith Cathy (618) 939-4979</p>
---	--

**(3) INSPECTION OF INTERIOR LINING OF TANKS:**

- (a) *Number and size of tanks being inspected:* (TK # 3, 4) - 5,000 gallons, (TK # 5, 6) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Product stored in each tank:* (TK # 3) - Diesel Fuel, (TK # 4) - E-85, (TK # 5, 6) - Gasoline
- (d) *Manway accessible at grade:*

- (4) **Any tank that has been out of service for a twelve-month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for the inspection of the existing interior lining only. No repairing, upgrading, or interior lining is authorized with this permit.**
- (5) **The owner must notify this Office when completion of tank interior inspection has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**
- (6) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Contractor states there are existing manways. The underground storage tank system (to include the existing lining material) for tank #4 must be compatible with E-85, as indicated in section 170.470, 170.500, 170.530(d)(2), 170.530(j), and 170.540(a) of Title 41 of the Illinois Administrative Code, and as indicated in policy #06-PCS-005 regarding the use of alternative fuels in underground storage tanks.

<p><b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Superior Equipment Co Inc        3283 Ivanhoe Ave        St. Louis, MO 63139</p>	<p>Contact Person: Greg Spiros        Phone:        Contractor Registration #    Exp.</p>

Sincerely,

*James J. Coffey*

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)