



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-028611
Permit # 01019-2007REM
Request Rec'd 07/12/2007
Amended Date
Approval Date 7/12/2007 JC
Permit Expires 1/12/2008

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Village Of Lombard 255 E Wilson Rd Lombard, IL 60148 Contact: Jones John H (708) 620-5758	(2) FACILITY - name and address where tanks are located: Lombard Fire Station 1 50 E St Charles Rd Lombard, Du Page Co., IL Contact: Jones John (708) 620-5750
---	---

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed:* (TK # 3, 4) - 1,000 gallons
- (b) Product stored in each tank:* (TK # 3, 4) - Unknown
- (c) Reason of tanks being removed:*
- (d) If tank(s) is leaking, indicate IEMA incident number:*
- (e) Date each tank was last used:* (TK # 3, 4) - 12/31/1973

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 170.640 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.**

- (5) SPECIAL CONTINGENCIES:** Tanks are pre-74 according to Dan Coyne at Aces Demolition - 07/12/07.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Aces Demolition 31 W 780 Poss Road	Contact Person: Phone: Contractor Registration # Exp.
--	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 6/07)