



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1043847
Permit # 01253-2022UPG
Request Rec'd 11/11/2022
Amended Date
Approval Date 11/15/2022 DS
Permit Expires 5/16/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Dayton Freight Lines, Inc. 6450 Poe Avenue, Suite 311 Dayton, OH 45414</p> <p>Contact: Jordan Karson (937) 235-1959</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Dayton Freight Lines, Inc. 3465 American Road Rockford, IL 61109</p> <p>Contact: Troy Ramey (937) 235-1959</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 15,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX*
- (d) Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1, 2) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Please see attached scope of work. We are adding one new fuel island and installing new dispenser and Bravo UDC on the new island next to their already existing 2 fuel islands. The new fuel island will get a new island form. We will connect new Ameron/Dualoy LCX Fiberglass into the existing piping run of the existing UST's to connect piping to the new fuel island. We will be replacing the existing dispensers on the existing fuel islands with new dispensers and new Bravo UDC's. The 2 existing island will not be replaced with new island forms, using their existing island forms and setting the new dispensers on these existing islands. That is why i picked reconstructing islands so i could explain each island from. The existing 2 lane 2 column canopy will be taken and a new 3 column - 2 lane canopy will be installed. We will re-use their existing TLS350. We are setting a new 4000 gallon DEF UST. Attached scope of work explains it more in detail. Thanks.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.

Contact Person: Bryan Estes

850 Brenkman Drive
Pekin, IL 61554

Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File