



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2010685
Permit # 01261-2022REM
Request Rec'd 11/17/2022
Amended Date
Approval Date 11/17/2022 DS
Permit Expires 5/17/2023

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083</p> <p>Contact: John Graham (847) 223-3710</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Lake Zurich #3 1 N. Rand Road Lake Zurich, IL 60047</p> <p>Contact: Lisa Railton (847) 223-3710</p>
--	--

(3) REMOVAL OF PIPING:

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 1) - 8,000, (TK # 2, 3) - 6,000, (TK # 6) - 12,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES : Removing the existing product piping between the existing tanks and the existing dispenser islands (inclusive of existing UDC's). Removing the existing vent piping as well. This is being done as part of the piping replacement project per permit #00886-2022UPG.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 3/8/2023

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File