



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2026095
Permit # 01267-2022REM
Request Rec'd 10/03/2022
Amended Date
Approval Date 11/18/2022 SB
Permit Expires 5/18/2023

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>First American Bank Trust #F89-158 4635 Coyote Lakes Circle Lake in the Hills, IL 60156</p> <p>Contact: David Hidding (847) 783-1812</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Dana Plastic Container Corporation 200 W Central Rd Roselle, IL 60172</p> <p>Contact: Richard Kane (847) 783-1812</p>
---	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 2) - 10,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 2) - #2 Fuel Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 2) - 1/1/1986*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES** : Remove product by vacuum tanker truck bonded and grounded to UST system. Excavate to top of tank and stockpile excavated soils for backfill and sampling. Check LEL/UEL of UST and remove vapors if present. Excavate and remove UST from ground, Check LEL/UEL of UST and remove vapors if present. Open and clean UST with proper PPE and trained personnel. Collect contents from cleaning operations within 55 gallon drums and characterize for proper disposal. Remove UST for final destruction off-site. Collect site assessment samples from the excavation. Backfill materials excavated.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Inland Environmental Remedial Services, Inc.
5 Bartlett Road
Barrington, IL 60010

Contact Person: David Frycek
Phone: (847) 677-7500
Contractor Registration # IL1005 Exp. 7/29/2024

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist
Division File