



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2005467
Permit # 01276-2022UPG
Request Rec'd 11/21/2022
Amended Date
Approval Date 11/21/2022 DS
Permit Expires 5/23/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60642</p> <p>Contact: Roy Hupke (708) 229-5241</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Little Company of Mary Hospital 2800 W. 95th Street Evergreen Park, IL 60805</p> <p>Contact: William Heisterman (708) 229-5241</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Flexible Double Wall OmegaFlex DoubleTrac , (TK # 6) Piping - Ball Valves*
- (d) Product to be stored in each tank: (TK # 6) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The underground tank has (1) existing 1 inch fuel supply line to the building generator. The existing fuel line will be replaced by the new. The new pipe will be (1) 1 inch Omegaflex brand pipe from the UST to the building. The route for the new pipe is not in the same trench as the old pipe. When the new pipe is installed the old pipe will be disconnected from the tank and drained and then abandoned in place under a separate permit. The change over from the old pipe to the new pipe will happen within a few hours so as not to take the generator system off line for more than 2 hours. There is no change to the tank top containment. The tank top containment is only a cycliner to keep gravel away and not a containment sump. There is NO change to the vent pipe, fill or other fuel system components. There is NO fuel return line.

Replaced piping exceeds 20 feet or 50% of the total pipe run.


NOTE: Piping is European suction

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Crowne Industries, Ltd.
651 S. Sutton Road #214
Streamwood, IL 60107

Contact Person: Robert Sumoski
Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2024

Sincerely,



Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File