



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453162

FOR OFFICE USE ONLY

Facility # 2045656
Permit # 01284-2022UPG
Request Rec'd 11/22/2022
Amended Date
Approval Date 11/22/2022
Permit Expires 5/23/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Vertiport USA - Chicago 1339 S. Wood Street Chicago, IL 60608 Contact: Daniel Mojica (312) 405-1960	(2) FACILITY - name and address where tanks are located: IMD Vertiport 1339 S. Wood Street Chicago, IL 60608 Contact: Daniel Mojica (312) 405-1960
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1) Piping - Other Submersible Pump, (TK # 1) Piping - Ball Valves , (TK # 1) Piping - Shear Valves , (TK # 1) Piping - Aboveground*
- (d) *Product to be stored in each tank: (TK # 1) - Jet A*
- (e) *Type of leak detection being used:*

Tank: (TK # 1) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS - 4c , (TK # 1) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Piping:

- (f) *Corrosion Protection being used:*

Tank:

Piping:

- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 1) Overfill Prev Device - Overfill Alarm*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive style with a horizontal line underneath the name.

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File