



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 3000688  
 Permit # 01316-2022UPG  
 Request Rec'd 12/06/2022  
 Amended Date  
 Approval Date 12/6/2022 DS  
 Permit Expires 6/6/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Madel, LLC          121 6th Avenue E.          Andalusia, IL 61232</p> <p>Contact: Raghu Acharya (309) 798-2229</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Andalusia Mart          121 6th Avenue          Andalusia, IL 61232</p> <p>Contact: Raghu Acharya (309) 798-2229</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 3,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 3) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


**(5) SPECIAL CONTINGENCIES :**

Premium line failed a 3rd party test. The leak seems to be next the ball Valve. We are not sure if it is the flex line or the ball valve.

**NOTE: A sump must be installed if one doesn't already exist**

<b>(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: (563) 344-0700 Contractor Registration # IL2034 Exp. 9/28/2024

Sincerely,



---

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File