



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7047055
Permit # 01345-2022UPG
Request Rec'd 12/13/2022
Amended Date
Approval Date 12/13/2022 DS
Permit Expires 6/13/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 10601 N. Penn Oklahoma City, OK 73120</p> <p>Contact: Jerrod Marsh (405) 834-0311</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Love's Travel Stop #803 1900 The Hill Ave Marion, IL 62959</p> <p>Contact: Kim Tarver (405) 834-0311</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 7, 9, 10, 11) - 3,000, (TK # 8, 12) - 8,000, (TK # 13) - 7,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 7, 8, 9, 10, 11, 12) - Motor Oil, (TK # 13) - Used Oil*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 7, 8, 9, 10, 11, 12, 13) Leak Detect - Piping - Piping Sump Sensors Not Regulated

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : This site will come up for sump testing. The transition sumps have sump sensors and interstitial monitoring is being used for the line leak detection. The lines associated with this system are European suction and therefore should be exempt from the testing. I selected non-discriminating sensors as equipment to be installed for all tanks to allow me to get to this point on the permit application. There are already sensors installed and we would like to simply change the status of the sensors to that of non-regulated status because of the European suction classification. We will not be installing any new sensors. Love's would like to keep the sensors for extra protection but change the status to non-regulated to avoid unnecessary testing. Thank you kindly.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Bryan Estes
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File