



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2008987
Permit # 01378-2022UPG
Request Rec'd 12/22/2022
Amended Date
Approval Date 12/22/2022 DS
Permit Expires 6/22/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Crest Hill Investors, LLC 221 Pine Street, 4th Floor San Francisco, CA 94104 Contact: Dean Stockwell (415) 616-5140	(2) <u>FACILITY</u> - name and address where tanks are located: Crest Hill Marathon 7-Eleven 1800 Plainfield Road Crest Hill, IL 60435 Contact: Troy Bryant (847) 915-9547
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 8) - 4,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 8) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 8) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replace shear valve under diesel dispenser. Will have line test before opening.

NOTE: A UDC must be installed if one doesn't already exist

(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Hoyt Ary Phone: (708) 478-6190 Contractor Registration # IL002275 Exp. 5/21/2024
---	---

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File