



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 7015186
Permit # 01373-2022UPG
Request Rec'd 12/20/2022
Amended Date 12/28/2022 DS
Approval Date 12/20/2022 DS
Permit Expires 6/21/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Southern FS, Inc. 2002 East Main Street P.O. Box 728 Marion, IL 62959 Contact: Doug Fox (618) 993-2833	(2) FACILITY - name and address where tanks are located: Southern F.S. Fuel 24 1501 East DeYoung Marion, IL 62959 Contact: Carol Fletcher (618) 993-2833
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 562, 563, 564) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 562) - Gasoline - Regular, (TK # 563) - Gasoline - Premium, (TK # 564) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 562, 563, 564) Leak Detect - Tank - Automatic Tank Gauging*
 - Piping: (TK # 562, 563, 564) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: Leak detectors at this site are Incon TS-LLD which wire directly into the submergible pump wires and does not use communication wires. The leak detectors we sold with the new system require a communication cable ran from the tank monitor to the leak detectors. The site does not have a low voltage conduit running to the submergible tank sumps. After speaking with the customer about options they have opted for us to install the new tank monitoring system, onstall mechanical leak detectors instead of the Electronic leak detectors due to site would have to be excavated in order to get conduits ran and wires pulled.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Mid-South Steel Products, Inc.
2071 Corporate Circle Drive PO Box 277
Cape Girardeau, MO 63703

Contact Person: Billy Thorne
Phone: (573) 335-5529
Contractor Registration # IL1194 Exp. 8/17/2024

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File