



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2044021
Permit # 00965-2022UPG
Request Rec'd 09/06/2022
Amended Date 12/29/2022 DS
Approval Date 9/7/2022 DS
Permit Expires 3/8/2023

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: DIL Foods, Inc. 5300 Bratt Skokie, IL 60077 Contact: Minhaz Lakhani (847) 226-6682	(2) FACILITY - name and address where tanks are located: Evanston Shell 2494 Oakton Street Evanston, IL 60202 Contact: Minhaz Lakhani (847) 338-2088
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Steel Single Wall Piping , (TK # 2) Piping - Other Steel Riser, (TK # 2) Piping - Other Submersible Pump, (TK # 2) Piping - Ball Valves , (TK # 2) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 2) - E-85*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 2) Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 2) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Amendment Reason: During the work it was discovered that the existing E85 product ELLD and the existing E85 product shear valve were already compatible with the product. These two items will be removed from the permit application.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File